

From: Jason Moran jmoran2@williams.edu
Subject: LSF & Police Station Water Connection
Date: July 16, 2018 at 8:49 AM America/New_York
To: Jason Hoch jhoch@williamstownma.gov, Timothy Kaiser tkaiser@williamstownma.gov



Jason and Tim,

No issues with you tapping into our existing water line on the access road to the LSF. It would be helpful to understand when this work will take place so I can make everyone aware. Also, would it be possible to install a separate valve down stream from your tap so that each building, the LSF and the Police Station, could be isolated individually? In the future, if we need to turn the water off to our building, we would have to do that in RT 7 which would shut water off to your building as well. Let me know your thoughts.

Thanks

Jason Moran
Senior Project Manager
Williams College
54 South Street
Williamstown, MA 01267
p: 413-597-4527
f: 413-597-4141
jmoran2@williams.edu