

From: Jason Hoch jhoch@williamstownma.gov
Subject: RE: LSF & Police Station Water Connection
Date: July 16, 2018 at 11:23 AM America/New_York
To: Jim Hanifan jhanifan@cbaarchitects.net, ACG Group acg@acgpm.com



Recommendation from public works department with expectation of much easier connection than Route 7. Tim at DPW can run through their thinking on this.

On Jul 16, 2018, 9:50 AM -0500, ACG Group <acg@acgpm.com>, wrote:

Good Morning Jason,

It is not clear to me why we would want to change the water service from RT 7 to the Access Road?

Besides redesign of water main, this will have an cost impact to the budget. I am not sure what the benefit is?

Thanks,

Greg Devlin

From: Jason Hoch <jhoch@williamstownma.gov>
Sent: Monday, July 16, 2018 9:39 AM
To: ACG Group <acg@acgpm.com>; Jim Hanifan <jhanifan@cbaarchitects.net>
Cc: Timothy Kaiser <tkaiser@williamstownma.gov>
Subject: Fwd: LSF & Police Station Water Connection

Gentlemen -

A change for water service. Should be easier overall. Greg, please feel free to coordinate with Tim, our DPW Director on this.

Thanks

Jason

----- Forwarded message -----

From: Jason Moran <jmoran2@williams.edu>
Date: Jul 16, 2018, 7:49 AM -0500
To: Jason Hoch <jhoch@williamstownma.gov>, Timothy Kaiser <tkaiser@williamstownma.gov>
Subject: LSF & Police Station Water Connection

Jason and Tim,

No issues with you tapping into our existing water line on the access road to the LSF. It would be helpful to understand when this work will take place so I can make everyone aware. Also, would it be possible to install a separate valve down stream from your tap so that each building, the LSF and the Police Station, could be isolated individually? In the future, if we need to turn the water off to our building, we would have to do that in RT 7 which would

shut water off to your building as well. Let me know your thoughts.

Thanks

Jason Moran

Senior Project Manager

Williams College

54 South Street

Williamstown, MA 01267

p: [413-597-4527](tel:413-597-4527)

f: [413-597-4141](tel:413-597-4141)

jmoran2@williams.edu